

GENERAL EMERGENCY ALARM SYSTEM

Power Distribution Box

220VAC/24VDC, they can change-over automatically. It with power failure alarm and AC transformer features. 6 zones bells to output. Each zone max. current is 10A. Total bell current of WYC-1 is ...

- ISO9001 Supplier
- Class Certificate
- Export Supply

	<div style="background-color: #1a3d3d; color: white; padding: 5px;">Key Highlights</div> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 5px;"> <tr> <td style="padding: 5px;">Category</td> <td style="padding: 5px;">General Emergency Alarm System</td> </tr> <tr> <td style="padding: 5px;">Standard</td> <td style="padding: 5px;">DIN</td> </tr> <tr> <td style="padding: 5px;">Certificate</td> <td style="padding: 5px;">ABS, LR, BV, DNVGL, NK, KR, IRS, RMRS, CCS</td> </tr> </table> <div style="margin-top: 10px; padding: 5px; background-color: #f0f0f0;"> <p>We can supply according to your requirement, drawings, class certificate needs, and delivery schedule.</p> </div>	Category	General Emergency Alarm System	Standard	DIN	Certificate	ABS, LR, BV, DNVGL, NK, KR, IRS, RMRS, CCS
Category	General Emergency Alarm System						
Standard	DIN						
Certificate	ABS, LR, BV, DNVGL, NK, KR, IRS, RMRS, CCS						

Technical Specifications			
Category	General Emergency Alarm System	Model / SKU	Power-Distribution-Box
Standard	DIN	Certificate	ABS, LR, BV, DNVGL, NK, KR, IRS, RMRS, CCS
Warranty	12 Months unless specified otherwise	Origin	China

China Power Distribution Box:

220VAC/24VDC, they can change-over automatically.

It with power failure alarm and AC transformer features.

6 zones bells to output.

Each zone max. current is 10A. Total bell current of WYC-1 is 10A. WYC-1A is 20A.

Power supply can change to main 220V AC and emergency 220VAC according to users requirement. Then the bell voltage is 220VAC.

