

GENERAL EMERGENCY ALARM SYSTEM

Alarm Horn BD1-24R

Technology Parameter: 1. Power 1.1 AC220V/110V/50-60HZ 1.2 AC、DC24V 2.Working Current: 2.1Type BD1-220G ^ 0.1A 2.2Type BD1-220Q ^ 0.1A 2.3Type BD1-24R < 0.6A 3. Sound Class: 3.1Type BD1-220G: 110db 3.2Type...

ISO9001 Supplier

Class Certificate

Export Supply



Key Highlights

Category	General Emergency Alarm System
Standard	DIN
Material	Plastic
Certificate	ABS, LR, BV, DNVGL, NK, KR, IRS, RMRS, CCS

We can supply according to your requirement, drawings, class certificate needs, and delivery schedule.

Technical Specifications

Category	General Emergency Alarm System	Model / SKU	Alarm-Horn-BD1-24R
Standard	DIN	Material	Plastic
Certificate	ABS, LR, BV, DNVGL, NK, KR, IRS, RMRS, CCS	Warranty	12 Months unless specified otherwise
Origin	China		

CONTENTS

- Technology Parameter:
- 2.Working Current:
- 3. Sound Class:

Technology Parameter:

1. Power
- 1.1 AC220V/110V/50-60HZ
- 1.2 AC、DC24V

2.Working Current:

2.1Type BD1-220G ^ 0.1A

2.2Type BD1-220Q ^ 0.1A

2.3Type BD1-24R < 0.6A

3. Sound Class:

3.1Type BD1-220G: 110db

3.2Type BD1-220Q: 75db

3.3Type BD1-24R: 110db

4.Basic Frequency : 825HZ

5.General Alarm Priority, Other According To Conection Table

6.Sound Meet To Solas Requirement



7. Type of Designation

—



