

FIRE DETECTION AND ALARM SYSTEM

HY-M900KEIS Manual Fire Alarm Button

ISO9001 Supplier

Class Certificate

Export Supply

Color: Red Shell Material: ABS Fire Retardant Cable Gland: 2-PG16 Ex-Rating: Exia II CT5
Gb Voltage: DC15V-33V Current: <=5uA Alarm Current: <=30mA



Key Highlights

Category	Fire Detection and Alarm System
Standard	GB
Material	Red Shell Material:
Certificate	ABS, LR, BV, DNVGL, NK, KR, IRS, RMRS, CCS

We can supply according to your requirement, drawings, class certificate needs, and delivery schedule.

Technical Specifications

Category	Fire Detection and Alarm System	Model / SKU	HY-M900KEIS-Manual-Fire-Alarm-Button
Standard	GB	Material	Red Shell Material:
Certificate	ABS, LR, BV, DNVGL, NK, KR, IRS, RMRS, CCS	Warranty	12 Months unless specified otherwise
Origin	China		

China HY-M900KEIS Manual Fire Alarm Button:

Color: Red

Shell Material: ABS Fire Retardant

Cable Gland: 2-PG16

Ex-Rating: Exia II CT5 Gb

Voltage: DC15V-33V

Current: <=5uA

Alarm Current: $\leq 30\text{mA}$

